

When recorded return to:
Snyderville Basin Water Reclamation District
2800 Homestead Road, Park City, Utah 84098

ENTRY NO. 00854149

09/04/2008 09:18:25 AM B: 1947 P: 1469

Notice PAGE 1/1
ALAN SPRIGGS, SUMMIT COUNTY RECORDER
FEE 0.00 BY SNYDERVILLE BASIN SID



NOTICE OF CONDITIONS

Property : Summit Center, Bldg. C
2758 W. Rasmussen Road
Tax ID#: PP-49-F

The Private Lateral Wastewater Line for this property does not conform to Snyderville Basin Water Reclamation District (SBWRD) Specifications.

Deficiencies are as follows:

1. Cover over lateral does not meet SBWRD requirements. A minimum of 48" cover is required. The cover achieved was 3 feet 4 inches.
2. A 90 degree bend immediately downstream of the initial clean out on the trench drain line.

I am aware of the conditions and accept responsibility for any problems, and attendant costs, related to the use, maintenance, repair or replacement of this line. I acknowledge that Snyderville Basin Water Reclamation District is not responsible for this condition. SBWRD may record this document with the Summit County Recorders office and I understand this Notice will remain with the property in perpetuity.

Mike Alford, *allied Summit LLC*
Owner/ Signing Authority


Manager
Title

Sept. 2, 08
Date

State of Utah)

County of *Summit*)

On this *2* day of *September*, 20*08*, personally appeared before me *Mike Alford*, and proved to me on the basis of satisfactory evidence to be the person (s) whose name (s) is (are) subscribed to this instrument, and acknowledged that he (she/they) executed the same.



Kathleen J. Nelson
Notary Public