


**Salt Lake City
Corporation
Building Services**

451 South State Street,
Room 215
P.O. Box 145471
Salt Lake City, Utah 84114-5471
(801) 535-7752



11444072
08/03/2012 03:46 PM \$0.00
Book - 10042 Pg - 7945
GARY W. OTT
RECORDER, SALT LAKE COUNTY, UTAH
SL CITY BLDG SERVICE & LICENSE
PO BOX 145455
SLC UT 84114
BY: SLR, DEPUTY - WI 1 P.

CERTIFICATE OF NONCOMPLIANCE

Sidwell Number: **15-14-454-014-0000**

I, Ed Schoenfeld, Building Inspector, for the City of Salt Lake, do hereby certify that the following property does not conform to the building code provisions of Salt Lake City's Revised Ordinances as adopted:

1. Type of Building: **Residential**
2. Street Address: **1950 South 900 West #N2, Salt Lake City, UT 84116**
3. Legal Description: **UNIT N2, 1950 INDUSTRIAL PARK CONDO.**
4. Owner: **1932 S LLC, P.O. Box 27807, Salt Lake City, UT 84127**

I further certify that the building violations to be corrected are as follows:

You need a vacuum relief valve on the cold inlet to the water heater. Where is the trap primer? You also need a thermostatic mixing valve meeting ASSE 1070 for the lav max temperature set at 110 degrees.

A Certificate of Compliance and Correction shall be filed by this office when all work has been accomplished.


Ed Schoenfeld, Building Inspector

STATE OF UTAH)
)ss
COUNTY OF SALT LAKE)

On this 1 day of August 2012, personally appeared before me, Ed Schoenfeld, Building Inspector for Salt Lake City, Utah, who acknowledged that he/she issued the above certificate and that the statements contained therein are true.


Notary Public, Residing at Salt Lake City, Utah

