

COMMUNITY & ECONOMIC DEVELOPMENT
Civil Enforcement
349 South 200 East, Suite 400
PO Box 145481
Salt Lake City, UT 84114

11965453
12/19/2014 04:10 PM \$0.00
Book - 10283 Pg - 5975
GARY W. OTT
RECORDER, SALT LAKE COUNTY, UTAH
SL CITY HOUSING & NEIGHBORHOOD
DEVELOPMENT
PO BOX 145481
SLC UT 84114-5481
BY: KRP, DEPUTY - MA 1 P.

ABSTRACT OF FINDINGS AND ORDER

I, Diana Hansen, being duly sworn, deposed, and say that I am the Secretary of the Salt Lake City Housing Advisory and Appeals Board, and that on the 13th of November, 2014, Case Number: HAZ2014-01504 was reviewed by the Administration Hearing Officer. The Appellant, Garbett Construction, requested on the property address of 180 North Main Street, Salt Lake City, an appeal on:

- The spacing between the openings for all interior guardrails is excessive.


DECISION:

- Granted approval by the Administrative Hearing officer for excessive spacing of all interior guardrails up to 9 inches.

The legal description of the property being as follows:

BEG NW COR LOT 5, BLK 93, PLAT A, SLC SUR; E 20 RDS; S 79 FT; E 20 FT; S 8 FT; E 29.5 FT; S 78 FT TO S LINE LOT 6; W 33 FT; N 8.25 FT; W 77.5 FT; N 8.25 FT; W 269 FT TO W LINE LOT 5; N 148.5 FT TO BEG.


Parcel Number: 09-31-309-033


Diana Hansen, Secretary

State of Utah)
)ss
County of Salt Lake)

The foregoing instrument was acknowledged before me this 18th day of December, 2014, by Diana Hansen, Secretary to the Housing Advisory and Appeals Board.




NOTARY PUBLIC, residing in Salt Lake
County, Utah